

FIRE PREVENTION WING

From :

**The District Officer
Fire Service Station
Chevella,
Hyderabad.**

To,

**Creekside International School
Gandipet X Road, Opp VIS Eng
Aziznagar Village
Hyderabad**

Rc.No.121/AD/FPW/GUMC/2023, dated: 13.01.2023

Sir,

Sub: Greater Hyderabad Municipal Corporation - Multi Storied Building - Creekside International School, Opp; VIT Engineering College, Aziz Nagar, Gandipet X Road, Hyderabad Issue of **FIRE NO OBJECTION CERTIFICATE**- Regarding.

Ref: 1) IORC.No.45/FPW/AD/HO/2009 Commissioner & GHMC. Hyderabad.
2) Proceed R.No.5041/87/97, dt. 12.03.2010 of the Director General of State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
3) Application No.Nil dated: 13.01.2023 of C/o Creekside International School, Opp; VIT engineering College, Aziz Nagar, Gandipet X Road. Hyderabad

Under the power delegation vide reference 1" & 2" the inspection committee of the Fire Prevention Wing has inspected the existing School building Creekside International School, Opp;VIT Engineering College, Aziz Nagar, Gandipet X Road, Hyderabad on 10.01.2023 and submitted the following report.

The existing school building consisting of Ground + First Floor with a height of 13.70 Mtrs ., for Educational Occupancy (School). Now the Management has submitted application for the issuance of FIRE NO OBJECTION CERTIFICATE for occupancy.

PARTICULARS OF THE BUILDING :

a)	Address of the building	Creekside International School, Opp; VIT Engineering College, Aziz Nagar, Gandipet X Road, Hyderabad
b)	Built-up area/height of the building	914.43 Sq.Mtrs./13.70 Mtrs
c)	No. of blocks/Floors	C + Ground + 3 Floor
d)	Type of occupancy ..	Educational Building

FLOOR WISE DETAILS:

S.No.	Floors	Area in Sq. Meters	Occupancy (Educational/Hostel/Dormitory occupancy)	Occupant Land as given the management
	Cellar Area	721.5	Educational	
	Ground Floor	1924.61	Educational	
	1 st Floor	1924.61	Educational	
	2 nd Floor	1924.61	Educational	
	3 rd Floor	1153.50	Educational	
	Total Area	7648.83		

The management has provided Two Internal staircase and Two External with a width of 01.20 meter and One Main Gate with a width of 03.00 mtrs.

The occupant load as per area is 120/4-30 Nos. The management has given the occupant load of 60 per floor and exit width required $1 \frac{60}{25} = 02.40$ units of 0.50 meters i.e ., 01.20 meters and aggregate exit width provided is 01.20 meters.

OPEN SPACES ALL ROUND BUILDING AREA:

	Open space required as per G.O.Ms.No.86, M.A. & U.D. (M) Dept ., dated: 03.03.2006 under Table-III	Open the space provided by the builder	
Front Side	03.00 MUns	03.60-MLrs	
Side – 1	01.00 Mtrs	01.20 Mtrs	
Side – 2	01.00 Mtrs	01.60 Mtrs	
Rear Side	01.00 Mtrs	01.20 Mtrs	

Strict compliance with all fire safety provisions as per the conditions of provisional No Objection Certificate issued vide Part 4 National Building code of India and at building rules. particularly the following should be ensured at all time


1. No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
2. Every room with a capacity of 45 students shall be maintained obstruction free minimum two doorways.
3. Fire Extinguishers:

The following fire extinguishers shall be maintained in working condition at all times as per IS 2100-1997.

1. Fire Buckets (water and sand) 04 Nos (Provided)
2. Water Column Fire Extinguishers 09 Nos., capacity 01 No (Provided)
3. ABC Pressured Type Fire Extinguishers 05 Kg Capacity 03 Nos (Provided)
4. Terrace Water Tank 9,000 Ltrs., capacity (Provided)-5,000Ltrs
5. Underground water Tank 5,000 Ltrs. (Provided) 10000Ltrs
6. First Aid Box 02 Nos. Provided)
7. Miniature Circuit breakers (Provided)

In view of all the, FIRE NO OBJECTION CERTIFICATE for Occupancy from fire Safety Point of View is issued subject to the following conditions:

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/occupancy or building regulations. The Owner/Occupier shall comply the Building Rules/Govt. Orders as applicable.
2. Evacuation plan showing exit routes and recommended action plan be displayed conspicuous locations shall be exhibited at all times, all escape/exit routes shall not be blocked or encroached.
3. Fresh NOC would be required for any change in occupancy as per NBC and building bye/laws.
4. The NOS Certificate issued is not relevant for claiming ownership of the property.
5. The Management has to maintain Fire Safety Measures at all times in good working conditions as soon during the inspection.
6. Any Loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
7. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
8. All occupants/security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
9. Additional/Alteration, if any, in the building may be verified by building authority.
10. The Fire Drills shall be conducted once in every six months for initial two years, thereafter once in every 6 months.
11. This FIRE NO OBJECTION CERTIFICATE for occupancy is valid for one year from the date of issue of this letter. It is the responsibility of the builder/occupier to apply for renewal of NOC, one month before expiry of the NOC


13/11/2023
STATION FIRE OFFICER
FIRE STATION CHEVELLA R.Dist.
The District Fire Officer,
Chevella, Hyderabad

Copies to :

1. Creckside Internal School,
Gandipet X Road, Hyderabad,